

Certificate Number: Durisol0119

Valid Until: 07/02/20

Durisol UK

Parkway,
Pen-Y-Fan Industrial Estate,
Crumlin,
NP11 3EF



Product: Durisol permanent formwork system

Conditions of approval;

The Durisol permanent formwork system incorporating the Parex render (as stated below) will satisfy the requirement of the Warranty Technical Manual subject to the following conditions:

1. The Durisol Permanent Formwork System used with the Parex Monorex GF Render Finish must be installed strictly in accordance with the BBA Agreement Certificate 10/4784 Product Sheet 2 dated 20 January 2012 & BBA Agreement Certificate 06/4400
2. The BBA Certificate specifically states the Durisol Permanent Formwork system and the Parex Monorex GF render finish can only be used in exposure zones of less than 75 litres per m². For meeting the requirements of our Technical Manual; this would limit this to Sheltered and Moderate Exposure zones as clarified in BS 5628 - 3 - 2005 (See also map in BRE report 262 Thermal Insulation: avoiding the risks)
3. That:
 - a. The Durisol Permanent formwork system should only be installed by installers who have been trained by the Certificate Holder
 - b. The Parex Monorex GF Render finish should only be installed by contractors approved by Parex Ltd(For Warranty purposes, we will require proof of the competency of the installers for both components on all projects.)
4. Assessments for Interstitial Condensation risk should be carried out on all projects.
5. A qualified structural engineer shall provide Structural calculations for each project, to prove the stability of the structure including consideration for the provision of movement joints. Details of such movement joints will be required to be assessed.
6. If Parex render is proposed in a coastal or very severe or severe exposure location, please refer to TSD.
7. This acceptance is only for the Durisol Permanent Formwork system and the Parex Monorex GF render finish (see BBA Certificate 06/4400 whilst remaining valid) above damp proof course (DPC) level and it is not for any other similar external render finish. In all other situations, the Durisol Permanent Formwork must be protected with a suitable external cladding with a separating drained cavity. (As Section 1.11 of BBA Certificate 10/4784 Product Sheet 1)

Premier Guarantee has awarded this Certificate to the company named above for the product described herein. This product has been assessed by Premier Guarantee as being fit for its intended use provided it is installed, used and maintained as set out in the System Approval Document.

Date: 07/02/2019

Signed: 